





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
<http://www.apragaz.com>
info@apragaz.com

NOTIFIED BODY EC CERTIFICATE OF CONFORMITY In accordance with module D - Production Quality Assurance of the Marine Equipment Directive 2014/90/EU (As amended)		Certificate N° 02/IT/469-13-REV 0 Page 1/5
Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio, 4 IT - 27020 Torre d'Isola (Pavia) ITALY
<p>Concerned Equipment: Portable Fire Extinguishers</p> <p>Covered by: Our Notified Body EC Type Examination (module B)</p> <p>Summary: see pages 2/4 until 4/4</p>		
<p>This is to certify that the Quality Management System of the above mentioned manufacturer has been assessed against the requirements of annexe B-Module D of the Marine Equipment Directive 2014/90/EU as amended and conforms to the requirements for the equipments shown above. The approval is subject to the continued maintenance of the Quality System in accordance with the requirements of the above Directive, this shall be controlled by intermediate audits, inspections and surveys.</p>		
<p>The manufacturer is allowed to affix the marine CE mark  followed with our notified body identification n° 0029 to approved equipment in the conditions described in article 10 of the Directive.</p> <p style="text-align: center;">The approval is valid until 06/04/2020</p>		
Date of first issue : 17/05/2001	Name : Ch. Leplat	Position General Manager
Date of last extension: 06/03/2017		
Notified body identification number :	0029	Signature
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P4434/043	





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com

NOTIFIED BODY EC CERTIFICATE OF CONFORMITY
In accordance with module D - Production Quality Assurance
of the Marine Equipment Directive 2014/90/EU (As amended)

Certificate N°
02/IT/469-13-REV 0
Page 2/5

Manufacturer

Name

ANAF FIRE PROTECTION S.P.A.

Address

Via del Commercio, 4
IT - 27020 Torre d'Isola (Pavia)
ITALY

SUMMARY OF EC-TYPE EXAMINATION

Identification Trade name	Capacities	Product	Test pressure	Service temp. range	Technical Design Reference	Certificate Apragaz Mod B
CS2A	2 kg	Carbon dioxide	250 bar	-30°C / +60°C	00.752B.F000.00 Rev. C	02/IT/343
CS5A	5 kg	Carbon dioxide	250 bar	-30°C / +60°C	00.752M.F000.00 Rev. D	02/IT/343
PS1-X ABC	1 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12-652A-F000.00	00/IT/117
PS2-X ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12-652B-F000.00	03/IT/531
PS3-X ABC	3 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12-671C-F000.00	02/IT/344
FS6-EV	6 l	Water Based Stored Pressure	25 bar	0°C / +60°C	09.814 E.F.000.00	02/IT/443
FS9-EV	9 l	Water Based Stored Pressure	25 bar	0°C / +60°C	09.814 F.F.000.00	02/IT/443
FS6-E	6 l	Water Based Stored Pressure	25 bar	0°C / +60°C	09.815 E.F.000.00	02/IT/443
FS9-E	9 l	Water Based Stored Pressure	25 bar	0°C / +60°C	09.815 F.F.000.00	02/IT/443
PG1-KA	1 kg	Powder Cartridge Operated	22 bar	-20°C / +60°C	12.027 A.F000.00	03/IT/530
PS2-Y ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12.682 B.F000.00	03/IT/531
PS2-YN ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12.684 B.F000.00	03/IT/531
PS2-YZ ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12.252 B.F000.00	03/IT/531
PS2-YZN ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12.254 B.F000.00	03/IT/531
FS2-Y	2 l	Water Based Stored Pressure	20 bar	0°C / +60°C	09.450 B.F000.00	03/IT/531
PS6-F	6 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.245 E.F000.00	01/IT/146
PS6-G	6 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.246 E.F000.00	01/IT/146
PS9-F	9 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.245 F.F000.00	01/IT/146

Date of first issue : 17/05/2001

Name : Ch. Leplat

Position **General Manager**

Date of last extension: 06/03/2017

Notified body identification number :

0029

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting
Authority

Notified body reference :

P4434/043





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com

NOTIFIED BODY EC CERTIFICATE OF CONFORMITY
In accordance with module D - Production Quality Assurance
of the Marine Equipment Directive 2014/90/EU (As amended)

Certificate N°
02/IT/469-13-REV 0
Page 3/5

Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio, 4 IT - 27020 Torre d'Isola (Pavia) ITALY

SUMMARY OF EC-TYPE EXAMINATION

Identification Trade name	Capacities	Product	Test pressure	Service temp. range	Technical Design Reference	Certificate Apragaz Mod B
PS9-G	9 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.246.F.F000.00	01/IT/146
PS1-P ABC	1 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12.659.A.F000.00	00/IT/117
PS2-P ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	12.659.B.F000.00	03/IT/531
FS2-P	2 l	Water Based Stored Pressure	20 bar	+0°C / +60°C	09.659.B.F000.00	03/IT/531
CS2-ML	2 kg	Carbon dioxide	212 bar	-30°C / +60°C	50.707B.F000.00	05/IT/943
CS5-ML	5 kg	Carbon dioxide	212 bar	-30°C / +60°C	50.707M.F000.00	05/IT/943
PS6-EV ABC	6 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.810E.F000.00	06/IT/990
PS9-EV ABC	9 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.810E.F000.00	06/IT/990
PS6-E ABC	6 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.811E.F000.00	06/IT/990
PS9-E ABC	9 kg	Powder Stored Pressure	25 bar	-30°C / +60°C	12.811F.F000.00	06/IT/990
PS3-XC ABC	3 kg	Powder Stored Pressure	32 bar	-30°C / +60°C	12.241C.F000.00 rev. A	06/IT/994
PS4-H ABC	4 kg	Powder Stored Pressure	32 bar	-30°C / +60°C	12.241D.F000.00 rev. A	06/IT/994

Date of first issue : **17/05/2001**
Date of last extension: **06/03/2017**

Name : **Ch. Leplat**

Position **General Manager**

Notified body identification number :

0029

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting Authority

Notified body reference :

P4434/043





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com

NOTIFIED BODY EC CERTIFICATE OF CONFORMITY
In accordance with module D - Production Quality Assurance
of the Marine Equipment Directive 2014/90/EU (As amended)

Certificate N°
02/IT/469-13-REV 0
Page 4/5

Manufacturer	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio, 4 IT - 27020 Torre d'Isola (Pavia) ITALY



SUMMARY OF EC-TYPE EXAMINATION

Identification Trade name	Capacities	Product	Test pressure	Service temp. range	Technical Design Reference	Certificate Apragaz Mod B
PS6-H ABC	6 kg	Powder Stored Pressure	32 bar	-30°C / +60°C	12.241E.F000.00 rev. A	06/IT/994
PS9-H ABC	9 kg	Powder Stored Pressure	32 bar	-30°C / +60°C	12.241E.F000.00 rev. A	06/IT/994
PS6-J ABC	6 kg	Powder Stored Pressure	22 bar	-30°C / +60°C	32.455E.F000.00	09/IT/1895
PS6-JE ABC	6 kg	Powder Stored Pressure	22 bar	-30°C / +60°C	32.455E.F000.00	09/IT/1895
FS6-J	6 l	Water Based Stored Pressure	22 bar	+0°C / +60°C	09.460.E.F000.00	09/IT/1896
FS6-JF	6 l	Water Based Stored Pressure	22 bar	+0°C / +60°C	09.470.E.F000.00	09/IT/1896
PG1-B BC	1 kg	Powder Cartridge Operated	20 bar	-30°C / +60°C	03.039A.F000.00	11/IT/2515
PS1-PX ABC	1 kg	Powder A32 Stored Pressure	20 bar	-30°C / +60°C	32.075A.F000.00	14/IT/3348
PS1-PXN ABC	1 kg	Powder A32 Stored Pressure	20 bar	-30°C / +60°C	32.074A.F000.00	14/IT/3348
PS6-HH ABC	6 kg	Powder Stored Pressure	22 bar	-30°C / +60°C	32895.E.F000.00	14/IT/3349
PS6-HHZ ABC	6 kg	Powder Stored Pressure	22 bar	-30°C / +60°C	32897.E.F000.00	14/IT/3349
FG6-J	6 l	Water Based Cartridge Operated	22 bar	+0°C / +60°C	09.465.E.F000.00	14/IT/3350
FG6-JF	6 l	Water Based Cartridge Operated	22 bar	+0°C / +60°C	09.466.E.F000.00	14/IT/3350

Date of first issue : **17/05/2001**
Date of last extension: **06/03/2017**
Notified body identification number :

Name : **Ch. Leplat**
0029

Position **General Manager**

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting
Authority

Notified body reference :

P4434/043



Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com

NOTIFIED BODY EC CERTIFICATE OF CONFORMITY
In accordance with module D - Production Quality Assurance
of the Marine Equipment Directive 2014/90/EU (As amended)

Certificate N°
02/IT/469-13-REV 0
Page 5/5

Manufacturer

Name

ANAF FIRE PROTECTION S.P.A.

Address

Via del Commercio, 4
IT - 27020 Torre d'Isola (Pavia)
ITALY

SUMMARY OF EC-TYPE EXAMINATION

Identification Trade name	Capacities	Product	Test pressure	Service temp. range	Technical Design Reference	Certificate Apragaz Mod B
FG6-JC	6 l	Water Based Cartridge Operated	22 bar	+0°C / +60°C	09.467.E.F000.00	14/IT/3350
FS9-J	9 l	Water Based Stored Pressure	22 bar	+0°C / +60°C	09.860F.F000.00	11/IT/2373
FS9-JF	9 l	Water Based Stored Pressure	22 bar	+0°C / +60°C	09.870F.F000.00	11/IT/2373
PG1-VEGA ABC	1 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	32.546A.F000.00	15/IT/3593
PG2-VEGA ABC	2 kg	Powder Stored Pressure	20 bar	-30°C / +60°C	33.546B.F000.00	15/IT/3593
PG2-B ABC	2 kg	Powder Cartridge Operated	20 bar	-30°C / +60°C	33.390B.F000.00	15/IT/3594
PG1-B	1 kg	Powder Cartridge Operated	20 bar	-30°C / +60°C	32.390A.F000.00	13/IT/3306

Date of first issue : **17/05/2001**

Name : **Ch. Leplat**

Position **General Manager**

Date of last extension: **06/03/2017**

Notified body identification number :

0029

Signature

Notified body stamp :

APRAGAZ
Belgium
Inspecting
Authority

Notified body reference :

P4434/043

